Backrests Job Number: 493540



TEST REPORT FOR:

Avail Design Liberty DDA Toilet Backrest(R01R1W) Test to 1100 N loading force.

TEST DOCUMENTS:

AS 1428.1:2021

Design for access and mobility, Part 1 – General requirements for access – New building work, Section 12.2.4 - Backrests

LABORATORY REFERENCE:

493540

26th May 2022

Standard Test Form

AS 1428.1:2021

Backrests Job Number: 493540



TEST REPORT

This report may NOT be reproduced in part without written laboratory authorisation. The Novitatech Test Laboratory has no control over the selection of test samples. Any extension of the findings of this report to cover production items must be based on the production being truly represented by the sample(s). The Novitatech Test Laboratory is not responsible for information provided by the customer that may affect the validity of results in this test report

Job Number: 493540

PRODUCT

Name and Model No:

Avail Design Liberty DDA Toilet Backrest(R01R1W)

Serial/Batch No:

NA

Maximum user mass: Tested to 1100N / 112kgf

Documents used in report

AS 1428.1:2021 Section 14 - Grabrails

SUPPLIER

Name:

Avail Design

Address:

3/10 Rutherford Road, Seaford VIC 3198

Contact: David Sayers

Telephone: 0400 095 077 Email: dave@avail.design

Order no: Order date:

TESTING AUTHORITY

Name: Novita Children's Services, NovitaTech Test Laboratory

Address: 1 South Road, Thebarton, South Australia 5031

Telephone: (08) 8243 8289 Email: testing@novita.org.au

Testing supervisor: Greg Paini

Senior test technician Authorised signatory

Checked: Leonie Rich Perrett

Assistive Technology Technical Specialist

Dates of testing period: Date of issue of this report:

May 2022 26th May 2022



Isometric View of Sample

NATA Accredited Laboratory No. 2953
Accredited for compliance with ISO/IEC 17025 – Testing
This document shall not be reproduced, except in full.

Testers Initials: GP, LRP

Page 2 of 5

Standard Test Form

AS 1428.1:2021

Backrests Job Number: 493540



DETAILED PRODUCT DESCRIPTION

Name/model number:

Avail Design Liberty DDA Toilet Backrest(R01R1W)

Production or prototype sample:

Production

Material:

Stainless steel tubular frame with padded vinyl covered pad.

Fasteners supplied with rail:

3 x 6mm x 75mm stainless steel bugles, 1 x 6mm x 65 mm stainless steel bugle

Functional description:

Padded toilet backrest

Pre-test Inspection:

OK to test

PHOTOS OF SAMPLE (BEFORE TESTING)



Side View



Front View

Backrests Job Number: 493540



AS 1428.1:2021 DESIGN FOR ACCESS AND MOBILITY- SECTION 12.2.4

Reference	Test/Requirement	Specification	Result
Backrests Sh	all:		
12.2.4 (a)	Be capable of withstanding a force in any direction of 1100N	Shall be no visible deformation, loosening or rotation	PASS
12.2.4 (b)	Dimensions at the face of the pad	Vertical height of 150 to 200mm Width of 350 to 400mm	PASS (See remarks)
12.2.4 (c)	Have its face inclined	95° to 100° to the horizontal	PASS
12.2.4 (d)	Be centred on the WC pan centre line		Not assessed
12.2.4 (e)	Be located in the correct orientation to the top and front of the seat	Installation requirements	
12.2.4 (f)	Be located to allow the seat to remain in the raised position	Installation requirements	
12.2.4 (g)	Be capable of being removed and refitted		

Remarks:

Clause 12.2.4 (b) – Dimensions at the face of the pad comply with the requirements of the standard. It is the determination of this laboratory that the shape of the pad is not a requirement.

The backrest was attached to a flat, rigid vertical surface using supplied stainless steel 6mm x 75mm and 6mm x 65mm fasteners to simulate the normal mounting of the backrest grab rail to the wall. Forces were applied in the following directions:

- 1. Outwards away from the mounting surface
- 2. Inwards towards the mounting surface
- 3. Horizontally towards the left
- 4. Horizontally towards the right
- 5. Vertically upwards
- 6. Vertically downwards

The Avail Design Liberty DDA Toilet Backrest(R01R1W) was able to sustain the required 1100 N force in all directions without loosening or permanent deformation.

None. GP. End of remarks -----

The sample submitted for this test satisfies the relevant requirements of AS1428.1 (Section 12.2.4) for backrests grab-rails (except the methods indicated in this report as "not assessed" and/or tested with deviations).

PASS

Testers Initials: GP, LRP

Backrests

Job Number: 493540



Traceable Equipment Used For Measurements In This Report										
Gauge #	Gauge Type		Gauge #	Gauge Type						
TLE004	Standard finger Probe		TLE141	Tape Measure, 5 Metre						
TLE009	Cold Climate Chamber		TLE144	Stop Watch						
TLE010	Test Rig (Static Load Drop)	\boxtimes	TLE148	Protractor, Vernier						
TLE011	2 Drum Durability Rig		TLE151	Accelerometer						
TLE012	Stability Ramp - Static		TLE167	Test Masses, 25kg						
TLE016	Square, Steel - Large		TLE175	2 Drum Durability rig						
TLE018	Rule, Steel – 1,000 mm	\boxtimes	TLE176	Test Dummy						
TLE019	Reference Load Gauge		TLE179	Test Rig Prosthetics, Foot						
TLE024	Stability Ramp, Dynamic		TLE182	Multimeter						
TLE028	Spring Balance 0-100g		TLE183	Impact Pendulum						
TLE029	Spring Balance 0– 5kg		TLE184	Test Dummy						
TLE030	Spring Balance 0-20kg		TLE185	Inclinometer						
TLE032	Thermometer		TLE186	Inclinometer, small						
TLE049	Torque Wrench		TLE196	Test Rig Prosthetics, Knee						
TLE067	Tyre Pressure Gauge		TLE201	Load Cell	\boxtimes					
TLE068	Impact Mass, 25 kg Soccer		TLE203	Impactor						
TLE077	Force Gauge, RLG		TLE204	Pendulum Impact Hammer						
TLE084	Rule, Steel – 300mm		TLE205	Tape Measure, 8 Metre						
TLE087	Test Obstacles		TLE210	Test Obstacle, Threshold						
TLE105	Thermohygrograph	\boxtimes	TLE211	Prosthetic Set up Gauge						
TLE106	Scales, Digital		TLE212	Test Rig, Proof Test						
TLE112	Vernier Caliper, 200mm		TLE216	Load Pad, Seat Base						
TLE114	Spring Balance, 50kg		TLE218	Square, Steel - Small						
TLE131	Test Dummy		TLE220	DC Wattmeter						
TLE132	Test Dummy		TLE221	Temp/Humidity Meter						
TLE133	Test Dummy		TLE225	Caliper, Digital 200mm	\boxtimes					

Testing to AS 1428.1:2021 Clause 12.2.4 – Backrests, is not covered by Novitatech Test Laboratory's scope of accreditation Testing in this report is not NATA endorsed, however is conducted at the same facility, using the same quality and calibration systems, equipment and competent personnel.

NOTES:

- 1. Uncertainty of measurement (U_m) has been calculated for linear, angle, force, mass, temperature, cycles and count measurements and meets the referenced standards' specifications.
- 2. Kgf to N conversion calculations take into account any difference in standard gravity (g_n) to local measurement (g) obtained from the world geodetic system.
- 3. All testing was carried out in a controlled environment laboratory using methods set out in the Standards documents, all deviations and additions to the Standards' methods are noted in remarks.
- All instruments either carried valid calibration certificates throughout the test period or were checked against traceable Standards before and after use.
- 5. The NovitaTech Test Laboratory has no control over the selection of test samples. Any extension of the findings of this report to cover production items must be based on production being truly represented by the sample(s).
- 6. Any non-conformances are indicated in red.

FND OF REPORT		

Testers Initials: GP, LRP